

NTSB National Transportation Safety Board

Office of Railroad, Pipeline, and Hazardous Materials Investigations Office of Research and Engineering

Overview of SCADA Related Pipeline Accidents

Previous Accidents

- Brenham, TX, April 7, 1992
- Gramercy, LA, May 23, 1996
- Fork Shoals, SC, June 26, 1996
- Murfreesboro, TN, November 5, 1996
- Knoxville, TN, February 9, 1999
- Bellingham, WA, June 10, 1999
- Winchester, KY, January 27, 2000
- Greenville, TX, March 9, 2000
- Chalk Point, MD, April 7, 2000



Brenham, Texas





Brenham, Texas









```
GRYV_ZACH_20
05/23/96 22:02:41 Plantation
       Upstream Gravity
       Value=61.6646 API = analog dev
       GRYV_ZACH_20
05/23/96 22:02:34 Plantation
       Mainline Pressure
       Value=328.829 PSI - analog dev
       GRYV_ZACH_20
05/23/96 22:02:30
       Garyville Zachary 20 products
                                     (-731.71, 15min (-890.7), 60min
       tine Balance ALARM
                               5min
       GRYV_ZACH_20
05/23/96 22:02:19 Garyville
       Suction Pressure
       Value=14.8148 PSI = analog dev
```




```
GRYV_ZACH_20
05/23/96 22:02:41 Plantation
       Upstream Gravity
       Value=61.6646 API = analog dev
       GRYV_ZACH_20
05/23/96 22:02:34 Plantation
       Mainline Pressure
       Value=328.829 PSI - analog dev
       GRYV_ZACH_20
05/23/96 22:02:30
       Garyville Zachary 20 products
       tine Balance ALARM 5min (-7)1.71, 15min (-8)0.7), 60min (-9)3.7)
       GRYV_ZACH_20
05/23/96 22:02:19 Garyville
       Suction Pressure
       Value=14.8148 PSI = analog dev
```



```
GRYV_ZACH_20
05/23/96 23:01:56
        Booster 31
        Issued command STOP by ripley at FPLXOS6
        GRYV_ZACH_20
05/23/96 23:01:52
        Booster 30
        Issued command STOP by ripley at FPLXOSS
        GRYV_EACH_20
05/23/96 23:00:30
        Garyville Zachary 20 products
 Line Balance ALARM 5min (-763.4), 15min (-2256.5), 60min (-7388.8)
2hr (-7443.5), 4hr (-7482.6), 24hr (-7546.6)
        GRYV_ZACH_20
05/23/96 22:51:10 Garyville
        Booster 22
        Uncommanded change to state RUN
```








- Historical records added to the online SCADA computer
- Computer system became unresponsive
- Meanwhile a pressure buildup occurred in the pipeline system which led to the rupture







- Once the SCADA system computer became operational, the controller restarted the pipeline
- After the controller received an alert from computerized leak detection software and a field report of a gasoline smell, he shut down the pipeline




Kingman, Kansas






Kingman, Kansas



Alarm



Kingman, Kansas



Drop in Pressure





NTSB